



WEST OF ENGLAND **FIRE** PROTECTION LIMITED



Unit 4, Taw Trade Park, Braunton Road
Barnstaple, North Devon. EX31 1JZ
Tel: 01271 377394 Fax: 01271 321711 Email: info@westfire.co.uk

Certificate of Inspection

VALID UNTIL THE LAST DAY OF THE CALENDAR MONTH - 12 MONTH FROM THE DATE OF ISSUE

CUSTOMERS NAME & ADDRESS

East Worlington Parish Hall
East Worlington
Witheridge
Crediton
Devon
EX17 4TS

ENGINEER

Andrew Cameron

DATE OF ISSUE

16-02-2021

SERVICE AGREEMENT NUMBER

WE6638

EQUIPMENT LISTING

- 1 X 9lt Water Extinguisher (Basic Service)
- 1 X 2kg Carbon Dioxide Extinguisher (NOTE-H Test due)
- 1 X 2kg Powder Extinguisher (Basic Service)
- 1 X 3lt Foam Extinguisher (Basic Service)
- 1 X Fire Blanket (Inspected)
- 1 X 2kg Carbon Dioxide Extinguisher (New R - Commissioned)

Guidance To Clients (BS5306 Part 3) Monthly Inspection.

It is strongly recommended that in addition to this annual service that a regular visual inspection of all fire extinguishers is carried out at intervals of at least monthly, to ensure that all appliances are in there proper positions and have not been discharged or suffered any obvious damage

**This certificate confirms that the equipment listed above has been serviced in
Accordance with BS5306: Part 3 2017 and passed fit for service**



Any non-conforming equipment will be listed on a separate rectification form